

Log No. 96274
 Permit No. _____
 Basin 76

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. ~~54074~~ 54074

1. OWNER Ed King Construction ADDRESS AT WELL LOCATION Stock Lane 780 Corrient Ct Fernley NV
 MAILING ADDRESS _____

2. LOCATION SE 1/4 NE 1/4 Sec. 15 T. 20 N/S R. 24 E Lyon County _____
 PERMIT NO. 21-157-17 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Dust</u>		<u>0</u>	<u>18'</u>	<u>18'</u>
<u>Gray Clay</u>		<u>18</u>	<u>36'</u>	<u>18</u>
<u>Clay + Sand</u>		<u>36'</u>	<u>110'</u>	<u>84'</u>
<u>Gravel</u>		<u>110'</u>	<u>140'</u>	<u>30</u>

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>13</u>	<u>.185</u>	<u>+1</u>	<u>20'</u>
<u>10 7/8</u>	<u>QUP</u>	<u>.375</u>	<u>20</u>	<u>140</u>

Perforations:
 Type perforation Sawed
 Size perforation 1/8 x 4
 From _____ feet to _____ feet
 From 120' feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140' feet

9. WATER LEVEL
 Static water level 57' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Clean

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Lead Drilling Inc Contractor
 Address PO 599 Silver Springs NV 89429 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0031841
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1877
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 4/27-05

Date started 4/27/05, 20 _____
 Date completed 4-27-05, 20 _____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20 GPM</u>	<u>Air Lift</u>	<u>2 Hr</u>

RECEIVED
 MAY 06 2005
 STATE ENGINEER'S OFFICE

