WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 96301
Permit No.
Basin 88

NOTICE OF INTENT NO. 55343

1. OWNER William Reidenbaugh
MAILING ADDRESS 5395 Cedarwood Dr.
Reno, NV 89511

ADDRESS AT WELL LOCATION 5395 Cedarwood

2. LOCATION SW 1/4 NW 1/4 Sec. 02 T 17N N/S R 19E E Washoe County
PERMIT NO. (Issued by Water Resources) 45-572-09 Parcel No. Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders coarse sand		0	100	100
Broken volcanic rock		100	155	55
Sandy brown clay		155	160	5
Broken rock brown clay				
coarse sand	X	160	270	110
Granite		270	278	8

Washoe County Well Permit # WL040295

RECEIVED
MAY 09 2005
STATE ENGINEER'S OFFICE

Date started 4/29/2005 , 19__
Date completed 5/2/2005 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30+		3

8. WELL CONSTRUCTION
Depth Drilled 278 Feet Depth Cased 278 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	278	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	278

Perforations:
Type perforation Machine cut
Size perforation 3/32 x 3
From 218 feet to 278 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 50 feet to 278 feet

9. WATER LEVEL
Static water level 105 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 5/3/2005

USE ADDITIONAL SHEETS IF NECESSARY