

mw-3

Plugged by Well Log 110634
STATE OF NEVADA

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

DIVISION OF WATER RESOURCES

OFFICE USE ONLY

FINALIZED MM
PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 96307
Permit No. _____
Basin 87

NOTICE OF INTENT No. 39425

1. OWNER Conrad Phillips Co ADDRESS AT WELL LOCATION 190 W. Plum St Reno, NV 89509
MAILING ADDRESS 1230 Washington St Suite 212 TEMPE, AZ 85281
2. LOCATION NW 1/4 NW 1/4 Sec. 24 T. 19 S. R. 19 E. MBD&M WASHOE County
PERMIT NO. M/D-1355 Parcel No. 019-051-01 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>SAND + GRAVEL</u>		<u>0</u>	<u>24</u>	<u>24</u>
<u>REDDISH BROWN SMALL COBBLES</u>				
<u>SILTY SAND + GRAVEL</u>		<u>24</u>	<u>36</u>	<u>12</u>
<u>COARSE SAND + SILT</u>		<u>36</u>	<u>40</u>	<u>4</u>

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet
HOLE DIAMETER (BIT SIZE)
From 0 Feet To 40 Feet
Inches _____ Feet _____
Inches _____ Feet _____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>	<u>Sch. 40</u>	<u>PVC</u>	<u>0</u>	<u>25</u>

Perforations:
Type perforation factory slotted
Size perforation 1020
From 25 feet to 40 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 23 Neat Cement
Placement Method: Pumped Concrete Grout
 Poured
Gravel Packed: Yes No
From 23 feet to 40 feet

9. WATER LEVEL
Static water level _____ feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

Date started 1/29/05
Date completed 1/26/05

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Robert Longshore Contractor
Address 32 Stokes Drive Dayton, NV 89403
Nevada contractor's license number issued by the State Contractor's Board 0010157
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2198
Signed Walt Steuberg
By driller performing actual drilling on site or contractor
Date 1/27/05

RECEIVED
05 MAR -1 AM 10:06
STATE ENGINEERS OFFICE

RECEIVED
MAY 09 2005

STATE ENGINEER'S OFFICE

39.505283°N NAD27 D.D.
119.805620°W