


REPORT NO. **A05.042**

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**



LOG NO. 96313  
PERMIT NO. \_\_\_\_\_  
BASIN 092B  
NOTICE OF INTENT NO. **56259**

1. OWNER Spencer Bitz  
MAILING ADDRESS **55 Freeport Blvd. # 19 Sparks, NV 89431**  
2. WELL LOCATION SW 1/4 SE 1/4 SEC. 11 T 20 R 19 E Washoe COUNTY  
PERMIT NO. \_\_\_\_\_ PARCEL NO. **552-084-16** SUBDIVISION NAME \_\_\_\_\_

ADDRESS OF WELL **3750 Sun Cloud Circle**

3. TYPE OF WORK			4. PROPOSED USE			5. WELL TYPE		
<input checked="" type="checkbox"/> New Well	<input type="checkbox"/> Replace	<input type="checkbox"/> Recondition	<input checked="" type="checkbox"/> Domestic	<input type="checkbox"/> Irrigation	<input type="checkbox"/> Test	<input type="checkbox"/> Cable	<input checked="" type="checkbox"/> Rotary	<input type="checkbox"/> RVC
<input type="checkbox"/> Deepen	<input type="checkbox"/> Plug	<input type="checkbox"/> Other	<input type="checkbox"/> Municipal/Industrial	<input type="checkbox"/> Monitor	<input type="checkbox"/> Stock	<input checked="" type="checkbox"/> Air	<input type="checkbox"/> Mud	

6. LITHOLOGIC LOG				
MATERIAL	STRATA	FROM	TO	THICKNESS
Multi Color Shale Rock & Yellow Clay		0	15	15
Gray, Blue, Yellow, Red Rock		15	120	105
Multi Color Rock, Dark Red Sandy		120		
Sticky Clay, Hard Purple Clay		120	150	30
Dark Green, Blue Volcanic Rock & Specs of Red Clay		150	190	40
Blue Green Rock, Specs of Clay		190	200	10
Multi Color Rock & Sands		200	210	10
Blue Green Fractured Rock	X	210	<del>234</del> 227	<del>14</del> 17

Notes : Lat: N 39 36.606  
Long: W 119 48.751

Date Started 5/5/05 Date Completed 5/6/05

7. WELL TEST DATA			
TEST METHOD	GPM	DRAWDOWN	TIME (HRS)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Develop	20+		1Hr.

RECEIVED  
05 JUL 11 AM 10:37  
STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION	
Depth Drilled <b>227</b>	Depth Cased <b>227</b>
HOLE DIAMETER (BIT SIZE)	
<b>10</b> Inches <b>0</b> Feet <b>50</b> Feet	
<b>8 1/2</b> Inches <b>50</b> Feet <b>227</b> Feet	

CASING SCHEDULE				
Size OD	Weight/Ft	Wall Thickness	From	To
<b>6 5/8</b>	<b>12.92</b>	<b>.188</b>	<b>+2' 7"</b>	<b>227</b>

PERFORATIONS:

Type Perforation **Factory** Size Perforation **3/32 X 3**

From **207** Feet to **227** Feet

From \_\_\_\_\_ Feet to \_\_\_\_\_ Feet

From \_\_\_\_\_ Feet to \_\_\_\_\_ Feet

SURFACE SEAL:  Yes  No SEAL TYPE:

Seal Depth **50**  Neat Cement

PLACEMENT METHOD:  Pumped  Concrete Grout

Poured  Bentonite

GRAVEL PACKED:  Yes  No

From **50** Feet to **227** Feet

9. WATER LEVEL

Static Water Level **145** Feet Below Land Surface

Artesian Flow \_\_\_\_\_ GPM \_\_\_\_\_ PSI

Water Temperature **Cool** F Quality **Clear**

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **Aqua Drilling & Well Service, Inc.**

Address **675 Edsion Way**  
**Reno, NV 89502**

NV. CONTRACTOR'S LIC. NO. **15291** DRILLER'S LIC. NO. \_\_\_\_\_ ON SITE **2189**

Signed *[Signature]*

By driller performing actual drilling on site or contractor

Dated **May 6, 2005**