



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 53592

1. OWNER MARTIN Motive ADDRESS AT WELL LOCATION 9900 Via Sequoia RAILROAD ST SILVER SPRINGS, NV  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION SW 1/4 SE 1/4 Sec 25 T 17 N/S R 24 E County LYON  
 PERMIT NO. 017-544-10  
 Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND & GRAVEL		0	18	18
BR CLAY		18	46	28
GRAVEL	<del>X</del>	46	68	22
BR SANDY CLAY		68	115	47
GRAVEL	<del>X</del>	115	155	40

RECEIVED  
 05 FEB 19 11 00 AM '07  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 155 Feet Depth Cased 155 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 11 Inches To 0 Feet  
0 Feet 155 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>14</u>	<u>.188</u>	<u>+1</u>	<u>15</u>
<u>6 3/8</u>	<u>4</u>	<u>3DR 21</u>	<u>15</u>	<u>155</u>

Perforations:  
 Type perforation GRINDER CUT  
 Size perforation .045" X 4"  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 145 feet to 155 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 56 Ft  Neat Cement  
 Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 56 feet to 155 feet

9. WATER LEVEL  
 Static water level 41 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality CLEAR

Date started 10 JAN 20 05  
 Date completed 10 JAN 20 05

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>18-20</u>		<u>1.5</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name \_\_\_\_\_ Contractor  
 Address BLAIN DRILLING & PUMP CO. INC.  
P.O. BOX 1255  
Carson City, NV 89702  
 Nevada contractor's license number 46498  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the 2167  
 Division of Water Resources, the on-site driller.  
 Signed Jack Dotson  
 By driller performing actual drilling on site or contractor  
 Date 10 JAN 05