WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 46324
Permit No.
Basin 103

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 53589

1. OWNER Robert Tohu
MAILING ADDRESS
ADDRESS AT WELL LOCATION 240 ELIZABETH

2. LOCATION NE ¼ SE ¼ Sec. 20 T. 17 N/S R. 22 E STOREY County
PERMIT NO. (Issued by Water Resources) Parcel No. 3-314-17 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| DIRT-ROCK | | 0 | 14 | 14 |
| BOULDERS | | 14 | 24 | 10 |
| BROWN CLAY-GRAVEL | | 24 | 68 | 44 |
| FRACTURED RED ROCK | | 68 | 125 | 57 |
| RED & BLACK LAVA ROCK | X | 125 | 195 | 70 |
| RED CLAY-GRAVEL | | 195 | 218 | 23 |
| BLACK FRAC ROCK | | 218 | 260 | 42 |
| BLACK GRAVEL | X | 260 | 293 | 33 |

RECEIVED 05 JAN 5 PM 4:59 STATE ENGINEER'S OFFICE

Date started 16 DEC, 2004
Date completed 18 DEC, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 15-18 | | 1.0 |

8. WELL CONSTRUCTION
Depth Drilled 293 Feet Depth Cased 293 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 5/8 Inches | | 0 Feet | 75 Feet |
| 9 7/8 Inches | | 75 Feet | 293 Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 14 | .188 | +1 | 13 |
| 6 5/8 | 4 | SDR21 | 13 | 293 |

Perforations:
Type perforation GRINDER CUT
Size perforation .045" X 4"
From feet to feet
From 253 feet to 293 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 51 ft
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 51 feet to 293 feet

9. WATER LEVEL
Static water level 242 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality CLEAR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BEAN DRILLING & PUMP CO. INC. (Contractor)
Address P.O. Box 1255 Carson City, NV 89702 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 46498
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167
Signed Jack Dotson (By driller performing actual drilling on site or contractor)
Date 20 DEC 04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627