COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 96333
Permit No.
Basin 101

NOTICE OF INTENT NO. 56330

1. OWNER Ken Edgemon
MAILING ADDRESS P.O. Box 747, Fallon, NV 89407

ADDRESS AT WELL LOCATION Ken Edgemon, 3149 St Clair Road, Fallon, NV 89406

2. LOCATION nw ¼ ne ¼ Sec 10 T 18 N R 28 E Churchill County

PERMIT NO. | Issued by Water Resources | 006-331-72 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	2	2
Brown Clay		2	6	4
Brown Sand		6	28	22
Gray Sand		28	36	8
Black Clay		36	41	5
Black Sand		41	54	13
Gray Sand		54	58	4
Black Clay		58	64	6
Black Sand		64	73	9
Brown Sand	XX	73	80	7

RECEIVED 05 MAY 16 AM 11:56 STATE ENGINEERS OFFICE

Date started 04/25, 20 05
Date completed 04/25, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 80 Feet Depth Cased 80 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	80 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6 pVC	3.82	.258	20	80

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 75 feet to 80 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☐ Neat Cement
Placement Method: ☒ Pumped ☒ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☒ No
From 50 feet to 80 feet

9. WATER LEVEL
Static water level 7 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling Inc (CONTRACTOR)
Address P.O. Box 1265 (CONTRACTOR)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1758
Signed
By driller performing actual drilling on site or contractor
Date 05/11/05

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com