COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 96336
Permit No.
Basin 101
NOTICE OF INTENT NO. ~~56326~~ 56324

1. OWNER Hawk Properties
MAILING ADDRESS 2171 W Williams Ave PMB 280
Fallon, NV 8406

ADDRESS AT WELL LOCATION Hawk Properties
1486 Meadowlark Dr
Fallon, NV 89406

2. LOCATION ne ¼ sw ¼ Sec 21 T 19 N R 28 E Churchill County

PERMIT NO. (Issued by Water Resources) | 008-283-19 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	3	3
Brown Sand		3	8	5
Brown Clay		8	22	14
Brown Sand		22	36	14
Gray Clay		36	39	3
Black Clay		39	45	6
Black Sand		45	53	8
Gray Clay		53	55	2
Gray Sand		55	68	13
Brown Sand	XX	68	73	5

RECEIVED
05 MAY 16 AM 11:56
STATE ENGINEERS OFFICE

Date started 04/27, 20 05
Date completed 04/27, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 73 Feet Depth Cased 73 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	73 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6 pVC	3.82	.258	20	73

Perforations:
Type perforation Saw Cut
Size perforation 1/8
From 68 feet to 73 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☐ Neat Cement
Placement Method: ☒ Pumped ☒ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 73 feet

9. WATER LEVEL
Static water level 17 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling Inc (CONTRACTOR)
Address P.O. Box 1265 (CONTRACTOR)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1758
Signed
By driller performing actual drilling on site or contractor
Date 05/11/05

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com