COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 96345
Permit No.
Basin 070
NOTICE OF INTENT NO. 52500

1. OWNER Vic Christison
MAILING ADDRESS 4185 West Piper
Winnemucca, NV 89445
ADDRESS AT WELL LOCATION 4185 West Piper
Winnemucca, NV 89445

2. LOCATION SW ¼ N 1/2 ¼ Sec 23 T 35 N R 37 E Humboldt County
PERMIT NO. (Issued by Water Resources) Parcel No. 14-084-10 Subdivision Name Lot 10 Block E

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	3	3
Sand/clay		3	20	17
Clay		20	25	5
Sand and gravel		25	70	45
Brown clay		70	75	5
Sand and gravel		75	105	30
Clay		105	115	10
Sand and Gravel		115	124	9
Clay		124	140	16
Sand and gravel		140	160	
Clay		160	170	
Sand and gravel		170	185	
Cobles		185	190	
Sand and gravel		190	198	
Brown clay		198	200	

RECEIVED 05 MAY 13 AM 11:09 STATE ENGINEERS OFFICE

Date started May 3, 20 05
Date completed May 5, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
60		4

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	150 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	15	188	+1	20'
8.625	8.76	.508	20	200'

Perforations:
Type perforation Screened
Size perforation 0.50
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 47'
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☒ Yes ☐ No
From 47' feet to 200' feet

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

9. WATER LEVEL
Static water level 82' feet below land surface
Artesian flow N/A G.P.M N/A P.S.I
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson & Sons Drilling, Inc. (CONTRACTOR)
Address 10760 Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed
By driller performing actual drilling on site or contractor
Date May 10,2005

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com