WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 96347
Permit No.
Basin 175

NOTICE OF INTENT NO. 55023

1. OWNER Placer Dome North America Bald Mt Mine
MAILING ADDRESS PO Box 2706 Elko NV. 89803
ADDRESS AT WELL LOCATION Maggie Basin Project Well MB-3

2. LOCATION SW ¼ SW ¼ Sec. 29 T. 24 N/S R. 58 E White Pine County
PERMIT NO. 72369 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	60	
Silt		60	190	
Sand + gravel		190	530	
gravel		530	600	
Clay		600	640	
gravel		640	700	
Clay		700	760	
Sand		760	775	
Clay		775	805	

RECEIVED 05 MAY 13 AM 11:07 STATE ENGINEERS OFFICE

Date started 4-2-05, 20
Date completed 4-22-05, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
300+		50

8. WELL CONSTRUCTION
Depth Drilled 805 Feet Depth Cased 800 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
28"	Inches	0 Feet	40 Feet
17 3/4	Inches	40 Feet	805 Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
20"		0.250	+1	40
10 75		0.250	+2	800

Perforations: full flow cover screen
Type perforation ~~0.100 inch slot size~~
Size perforation 0.100 inch slot size
From 345 feet to 465 feet
From 485 feet to 605 feet
From 635 feet to 705 feet
From 755 feet to 775 feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 805 feet

9. WATER LEVEL
Static water level 263.4 feet below land surface
Artesian flow G.P.M. ~~300~~ P.S.I.
Water temperature C °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name W DC Exploration & Wells Contractor
Address 580 W. Silver ST. Contractor
Elko NV 89801
Nevada contractor's license number issued by the State Contractor's Board 0012852
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed [signature] By driller performing actual drilling on site or contractor
Date 5-9-05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627