

OFFICE USE ONLY
 Log No. 916318
 Permit No. _____
 Basin 102

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 55029

1. OWNER ECO:logic ADDRESS AT WELL LOCATION 0180 SHERIDAN LANE
 MAILING ADDRESS 10381 Double R Boulevard GARDNERVILLE NV 89460-6546
RENO, NV, 89521

2. LOCATION NE 1/4 NE 1/4 Sec. 15 T. 12 N/S R. 19 E. M.D.R. Douglas County
 PERMIT NO. M/O-1364 +1219-15-001-020 Subdivision Name _____
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Granite Boulders		0	45	
Hard Granite		45	50	
Rock & D.G. (yellowish)		50	140	
Clay (yellow)		140	142	
Fractured granite & Decomposed granite mixed clay & granite		160	180	
white & gray fractured granite & D.G.		180	220	
Orange clay & D.G.		220	260	
white Feox				
Grey clay and D.G.		260	280	
Orange clay & D.G.		280	290	
Grey clay & D.G.		290	300	
Backgrout hole with neat cement		224	300	

8. WELL CONSTRUCTION
 Depth Drilled 300 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches 0 Feet 300 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>		<u>Sch 80</u>	<u>0</u>	<u>220</u>

Perforations:
 Type perforation slot
 Size perforation .040
 From 100 feet to 160 feet
 From 180 feet to 220 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 98'
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 98 feet to 224 feet

9. WATER LEVEL
 Static water level 34 feet below land surface
 Artesian flow 0 G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WDC Exploration & wells Contractor
 Address 580 west silver st. Elko Nevada 89801 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0012852
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2244
 Signed Randy Cines
 By driller performing actual drilling on site or contractor
 Date 4-28-05

7. WELL TEST DATA

TEST METHOD Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25</u>		<u>3</u>

Date started 4/18/05
 Date completed 4/27/05

RECEIVED
 05 MAY 31 AM 11:07
 STATE ENGINEERS OFFICE