

Log No. 96319
 Permit No. _____
 Basin _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 52102

1. OWNER Rocky Payne ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1017 Desert Jewel Ct 75 Desert Ct Rd
Reina NV 89511
 2. LOCATION NW 1/4 SW 1/4 Sec 5 T 89 R 24 E Lyon County _____
 PERMIT NO. 010-761-54 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Gravelly Clay Boulders</u>		<u>0</u>	<u>140</u>	<u>140</u>
<u>Broken Green & Black Rock</u>		<u>140</u>	<u>250</u>	<u>110</u>
<u>Broken Black & Brown Rock</u>		<u>250</u>	<u>320</u>	<u>70</u>
<u>Broken Black & Grey Rock</u>		<u>320</u>	<u>370</u>	<u>50</u>
<u>Broken Black & Green Rock</u>		<u>370</u>	<u>380</u>	<u>10</u>
<u>Broken Black & Grey Rock</u>		<u>380</u>	<u>460</u>	<u>80</u>
<u>Broken Black & Green Rock</u>		<u>460</u>	<u>500</u>	<u>40</u>
<u>Broken Black & Grey Rock</u>		<u>500</u>	<u>520</u>	<u>20</u>
<u>Broken Black & Green Rock</u>		<u>520</u>	<u>540</u>	<u>20</u>

8. WELL CONSTRUCTION
 Depth Drilled 540 Feet Depth Cased 540 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 540 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>12</u>	<u>540</u>

Perforations:
 Type perforation mill slot
 Size perforation 2/32
 From 360 feet to 380 feet
 From 460 feet to 540 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 55 feet to 540 feet

9. WATER LEVEL
 Static water level 395 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality HA

Date started 12-16, 2004
 Date completed 1-11, 2005

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air Lift</u>	<u>5 to 30</u>	<u>520</u>	<u>8</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Nevada Pump & Drilling Contractor
 Address PO Box 2227 Dayton NV 89403 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 6046357
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
 Signed Wm J. Long
 By driller performing actual drilling on site or contractor
 Date 1-30-05