

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Permit No. 107  
 Basin 107  
 NOTICE OF INTENT NO. 49484

1. OWNER Rick Nuzum ADDRESS AT WELL LOCATION 260 Chaparral Dr  
Smith, NV  
 MAILING ADDRESS PO Box 5086 GY NV 89410  
 2. LOCATION SE 1/4 NW 1/4 Sec 22 T 11 N/S R 24 E Lyon County  
 PERMIT NO. N/A Parcel No. 0978303 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Silt Brown Clay with Cobbles &amp; Gravels</u>		<u>0</u>	<u>145</u>	<u>145</u>
<u>Brown Clay</u>		<u>145</u>	<u>155</u>	<u>10</u>
<u>Silt Brown Clay Cobbles and Gravel &amp; Sand</u>		<u>155</u>	<u>175</u>	<u>20</u>
<u>Sand Gravel &amp; Cobbles with some Brown Clay</u>		<u>175</u>	<u>200</u>	<u>25</u>

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet  
 HOLE DIAMETER (BIT SIZE)  
10 5/8 Inches From 0 Feet To 200 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>158</u>	<u>0</u>	<u>20</u>
<u>6"</u>		<u>SDR 21</u>	<u>20</u>	<u>200</u>

Perforations:  
 Type perforation mill slot  
 Size perforation 3/32  
 From 150 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 200 feet

9. WATER LEVEL  
 Static water level 105 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality APP

Date started 4-14- 2004  
 Date completed 4-16- 2004

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name NEVADA PUMP & DRILLING  
 Address P.O. BOX 2227  
DAYTON, NV 89403  
 Nevada contractor's license number 46357  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 5/15/04

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air Lift</u>	<u>15-620</u>		<u>2.5</u>