WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 963662
Permit No.
Basin 103

NOTICE OF INTENT NO. 49475

1. OWNER: Cynthia Wunderlich
MAILING ADDRESS: PO Box 1003 Dayton, NV 89403
ADDRESS AT WELL LOCATION: #25 Doney Rd Dayton, NV 89403

2. LOCATION: NE ¼ SE ¼ Sec. 28 T. 16 N/S R. 21 (E) Lyon County
PERMIT NO. NO (Issued by Water Resources) Parcel No. 16-151-59 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Broken Brown Volcanic Rock and Clay		0	140	140
Broken Gray Volcanic Rock Grey Clay		140	220	80
Solid Grey Volcanic Rock with fractures		220	400	180

Date started 11-3, 2003
Date completed 11-12, 2003

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Airlift	20-30	360	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	400 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	240
6 5/8		.188	240	280
6 5/8		.188	280	360

Perforations:
Type perforation Mill Slot
Size perforation 3/32
From 240 feet to 260 feet
From 280 feet to 300 feet
From 360 feet to 400 feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 400 feet

9. WATER LEVEL
Static water level 145 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality —

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nevada Pump + Drilling (Contractor)
Address PO Box 2227 (Contractor)
Dayton, NV 89403
Nevada contractor's license number issued by the State Contractor's Board 46357
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed Marty Lyon (By driller performing actual drilling on site or contractor)
Date 12-15-03

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627