COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 96305
Permit No.
Basin 105
NOTICE OF INTENT NO. 49487

1. OWNER HAROLD & MARY WHEELER
MAILING ADDRESS 1604 VIEWMONT CRT.
GARDNERVILLE, NV 89410

ADDRESS AT WELL LOCATION 1600 Viemont Crt.
GARDNERVILLE, NV 89410
Viewmont

2. LOCATION SW ¼ NE ¼ Sec 34 T 13 (N) R 20 (E) DOUGLAS County

PERMIT NO. (Issued by Water Resources) | 1320-34-001-026 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
COBBLES & BR CLAY		0	60	60
BROWN CLAY		60	75	15
COBBLES & BROWN CLAY WITH GRAVELS		75	100	25
BR CLAY GRAVELS		100	120	20
GRAVELS AND SAND		120	150	30
GRAVELY BR CLAY		150	160	10

Date started 03/22, 20 04
Date completed 03/29, 20 04

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR LIFT	15	140'	2

8. WELL CONSTRUCTION

Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	160	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+2	20
6"		SDR 21	20	130

Perforations:
Type perforation MILL SLOT
Size perforation 3/32"
From 130 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100' ☒ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 160 feet

9. WATER LEVEL

Static water level 63 feet below land surface
Artesian flow NO G.P.M P.S.I
Water temperature COLD °F Quality N/A

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name NEVADA PUMP & DRILLING (CONTRACTOR)
Address PO BOX 2227 (CONTRACTOR)
DAYTON, NV 89403
Nevada contractor's license number issued by the State Contractor's Board 0046357
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed [signature]
By driller performing actual drilling on site or contractor
Date 04/16/04

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com