


COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**



OFFICE USE ONLY

Log No. 96366

Permit No. \_\_\_\_\_

Basin 106

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 52100

1. OWNER **RALPH & LINDA DOUGLAS**  
 MAILING ADDRESS **1319 JACOBSEN LN.  
 GARDNERVILLE, NV 89410**

ADDRESS AT WELL LOCATION **1530 MOSS CIR.  
 TOPAZ, NV 89410**

2. LOCATION NW  $\frac{1}{4}$  SW  $\frac{1}{4}$  Sec 18 T 10 N R 22 E DOUGLAS County

PERMIT NO. NA **1022-18-002-010** Subdivision Name NA

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
<b>SMALL BROKEN VOLCANIC ROCK</b>		<u>0</u>	<u>8</u>	<u>8</u>
<b>BROWN VOLCANIC ROCK W/ CLAY &amp; SILT</b>		<u>8</u>	<u>240</u>	<u>232</u>
<b>GREY VOLCANIC ROCK &amp; SILT</b>		<u>240</u>	<u>260</u>	<u>20</u>
<b>BROWN BROKEN VOLCANIC ROCK</b>	<u>X</u>	<u>260</u>	<u>285</u>	<u>25</u>
<b>BROWN VOLCANIC ROCK W/ CLAY SILT</b>		<u>285</u>	<u>295</u>	<u>10</u>
<b>BROWN VOLCANIC ROCKS BROKEN</b>	<u>X</u>	<u>295</u>	<u>320</u>	<u>25</u>
<b>BROWN VOLCANIC ROCK / CLAY</b>		<u>320</u>	<u>325</u>	<u>5</u>

8. WELL CONSTRUCTION				
Depth Drilled	<u>325</u> Feet	Depth Cased	<u>325</u> Feet	
HOLE DIAMETER (BIT SIZE)				
	From		To	
	<u>10 5/8</u> Inches	<u>0</u> Feet	<u>325</u> Feet	
	_____ Inches	_____ Feet	_____ Feet	
	_____ Inches	_____ Feet	_____ Feet	
CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188 STEEL</u>	<u>+2</u>	<u>325</u>

Perforations:  
 Type perforation MILL SLOT  
 Size perforation 3/32"  
 From 265 feet to 325 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 55 feet to 325 feet

9. WATER LEVEL  
 Static water level 91 feet below land surface  
 Artesian flow NO G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD °F Quality NA

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name NEVEAD PUMP & DRILLING  
 (CONTRACTOR)

Date started 11/12, 20 04  
 Date completed 11/19, 20 04

7. WELL TEST DATE			
TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<b>AIR LIFT</b>	<u>20</u>		<u>4 HOURS</u>

Address PO BOX 2227  
 (CONTRACTOR)  
DAYTON, NV 89403  
 Nevada contractor's license number issued by the State Contractor's Board 0046357  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790  
 Signed Monty Lopez  
 By driller performing actual drilling on site or contractor  
 Date 12-15-04