

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49479

1. OWNER Norman Hartz / Kirka Const ADDRESS AT WELL LOCATION 1932 Borda
 MAILING ADDRESS P.O. Box 665 Minden, NV 89423 Gardnerville, NV 89410
 2. LOCATION SW 1/4 NE 36 T 13 N/S R 20 E Douglas County
 PERMIT NO. N/A Issued by Water Resources 1320-36-001-020 Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Coarsely Brown Clay</u>		<u>0</u>	<u>240</u>	
<u>Brown Clay Silt</u>		<u>240</u>	<u>380</u>	
<u>Sandy Brown Clay</u>		<u>380</u>	<u>470</u>	
<u>Sand Gravel Some</u>				
<u>Brown Clay</u>		<u>470</u>	<u>500</u>	
<u>Sand Small Gravel</u>		<u>500</u>	<u>540</u>	
<u>Sandy Brown Clay</u>		<u>540</u>	<u>545</u>	

8. WELL CONSTRUCTION
 Depth Drilled 545 Feet Depth Cased 545 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 545
10 5/8 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>1 5/8</u>	<u>0 to</u>	<u>545</u>

Perforations:
 Type perforation Mill slot
 Size perforation _____
 From 485 feet to 545 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 545 feet

Date started 11-19, 2003
 Date completed 12-5, 2003

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air Lift</u>	<u>20 gal</u>	<u>500</u>	<u>4.5</u>

9. WATER LEVEL
 Static water level 375 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name NEVADA PUMP & DRILLING Contractor
 Address P.O. BOX 2227 Contractor
DAYTON, NV 89403
 Nevada contractor's license number 46357
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
 Signed Monty Lynn
 By driller performing actual drilling on site or contractor
 Date 12-10-03