

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 96379  
 Permit No. \_\_\_\_\_  
 Basin 105

NOTICE OF INTENT NO. 51889

1. OWNER Roger + Kim Sauln ADDRESS AT WELL LOCATION 371 Canyon Creek Crt Gardnerville, NV 89410  
 MAILING ADDRESS 3160 Zion Ln San Jose, Ca 95132  
 2. LOCATION 1/4 SE 1/4 Sec. 15 T. 12 N/S R. 19 E Douglas County  
 PERMIT NO. NO Issued by Water Resources 1219-15-002-036 Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>DG Cobbles Boulders</u>		<u>0</u>	<u>80</u>	<u>80</u>
		<u>80</u>	<u>140</u>	<u>60</u>
<u>Compact DG some Gobbles</u>				
<u>DG Cobbles</u>		<u>140</u>	<u>215</u>	<u>75</u>
<u>Compact DG</u>		<u>215</u>	<u>220</u>	<u>5</u>

8. WELL CONSTRUCTION  
 Depth Drilled 220 Feet Depth Cased 220 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet 220 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>138</u>	<u>12</u>	<u>20</u>
<u>6"</u>		<u>50R21</u>	<u>20</u>	<u>220</u>

Perforations:  
 Type perforation millislot  
 Size perforation 3/32  
 From 160 feet to 220 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 220 feet

Date started 7-7-04  
 Date completed 7-14-04

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR LIFT 10 to 15</u>	<u>200</u>	<u>4</u>

9. WATER LEVEL  
 Static water level 112 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality NH

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name NEVADA PUMP & DRILLING  
 Address P.O. BOX 2227 DAYTON, NV 89403  
 Nevada contractor's license number issued by the State Contractor's Board 46357  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 7-20-04