WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46386
Permit No.
Basin 107

NOTICE OF INTENT NO. 51868

1. OWNER BDR Const. (Thomas Tran) ADDRESS AT WELL LOCATION 42 Deer Pass Rd
MAILING ADDRESS P.O. Box 5086 Wellington, NV
Gardnerville NV 89410

2. LOCATION NW ¼ SW ¼ Sec. 20 T. 10 N/S R. 24 E. County
W½
PERMIT NO. N/A (Issued by Water Resources) Parcel No. 10-761-64 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Silt Clay Cobbles		0	175	
Large Boulder's				
Consolidated Large Boulders				
& Cobbles		175	280	
Brown Clay Slit		280	310	
Soft Volcanic Rock				
Brown Black	X	310	390	
Medium Hard Volcanic				
Rock Black Brown				
Some Broken Areas	X	390	460	
Volcanic Rock Some				
Brown Clay and				
Cobbles	X	460	500	

Date started 11-30, 2004
Date completed 12-13, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air Lift	20-30		7 Hrs

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	500 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+2	500

Perforations:
Type perforation Mill Slot + Air Perforation
Size perforation 2/32
From 200 feet to 500 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 55 feet to 500 feet

9. WATER LEVEL
Static water level 300 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality NA

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name NEVADA PUMP & DRILLING (Contractor)
Address P.O. BOX 2227 (Contractor)
DAYTON, NV 89403
Nevada contractor's license number issued by the State Contractor's Board 46357
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed Monty [illegible] (By driller performing actual drilling on site or contractor)
Date 12-20-04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627