

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 96396
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27562

1. OWNER CRHomes ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1051 W. Indian 1051 W. Indian
Pahrump, NV 89060

2. LOCATION NE 1/4 NE 1/4 Sec. 29 T 20S N/S R 53E E Nye County
 PERMIT NO. 39-062-15 Calvada Valley
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>brown loam</u>		<u>0</u>	<u>8</u>	<u>8</u>
<u>grey caleche</u>		<u>8</u>	<u>12</u>	<u>4</u>
<u>See next line</u>		<u>12</u>	<u>22</u>	<u>10</u>
<u>brey clay with caleche strings</u>				
<u>See next line</u>		<u>22</u>	<u>29</u>	<u>7</u>
<u>brown loam with caleche strings</u>				
<u>See next line</u>		<u>29</u>	<u>62</u>	<u>33</u>
<u>grey clay with caleche strings</u>				
<u>See next line</u>	<u>x</u>	<u>62</u>	<u>200</u>	<u>138</u>
<u>brown clay with caleche strings</u>				

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200+1 Feet

HOLE DIAMETER (BIT SIZE)
 From To
11 Inches 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>3.7</u>	<u>.280</u>	<u>0</u>	<u>200</u>

Perforations:
 Type perforation sawcut
 Size perforation .188

From 160 feet to 200 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL
 Static water level 68 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Strickland Construction Co., Inc. Contractor
 Address 5801 S. Homestead Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board 40277
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
 Signed _____ By driller performing actual drilling on-site or contractor
 Date 3-15-05

Date started 3/11/05, 19____
 Date completed 3/11/05, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift
 Draw Down

G.P.M.	(Feet Below Static)	Time (Hours)

QUANTITY RECEIVED
MAY 18 2005
LAS VEGAS OFFICE