WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 96391
Permit No.
Basin 105

NOTICE OF INTENT NO. 52097

1. OWNER Rex Cleary
MAILING ADDRESS PO Box 56 Genoa, Nv
ADDRESS AT WELL LOCATION 2398 Centennial Dr. Genoa, NV

2. LOCATION NE ~~N1/2~~ 1/4 NE 1/4 Sec. 09 T. 13 N/S R. 19 E. Douglas County
PERMIT NO. NA (Issued by Water Resources) 1319-09-510-001 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay + Silt with Grey Volcanic Rock		0	180	180
Broken Grey Volcanic Rock		180	190	10
Broken Grey Volcanic Rock with Brown Clay		190	330	40
Broken Grey Volcanic Rock		330	380	50
Hard Grey Volcanic Rock		380	385	105

Date started 8-12, 2004
Date completed 8-20, 2004

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air lift	30+		4

8. WELL CONSTRUCTION
Depth Drilled 385 Feet Depth Cased 385 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	385 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		188	+2	385

Perforations:
Type perforation mi 4 slt
Size perforation 3132
From 325 feet to 385 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 385 feet

9. WATER LEVEL
Static water level 147 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality NA

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name NEVADA PUMP & DRILLING (Contractor)
Address P.O. BOX 2227 DAYTON, NV 89403 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 46357
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed [signature] By driller performing actual drilling on site or contractor
Date 8-30-04

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627