

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 54108

1. OWNER Craig Martin ADDRESS AT WELL LOCATION 5960 Jumping Frog Juniper Street  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION SE 1/4 SW 1/4 Sec. 6 T. 17 N/S R. 25 E County \_\_\_\_\_  
 PERMIT NO. 17075-08 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
DIRT-ROCK		0	38	38
BROWN CLAY-ROCK		38	60	22
REDDISH-BROWN CLAY		60	80	20
LAVA ROCK		80	144	64
LAVA ROCK-CLAY		144	200	56
LAVA ROCK GRAVEL		200	240	40

8. WELL CONSTRUCTION  
 Depth Drilled 240 Feet Depth Cased 240 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 50 Feet  
9 7/8 Inches 50 Feet 240 Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>14</u>	<u>.188</u>	<u>11</u>	<u>20</u>
<u>6 5/8</u>	<u>4</u>	<u>SDR2L</u>	<u>20</u>	<u>240</u>

Perforations:  
 Type perforation Grinder Cut  
 Size perforation .045" x 4"  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 200 feet to 240 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50 ft  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 240 feet

9. WATER LEVEL  
 Static water level 175 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD Quality RED TINT

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name \_\_\_\_\_

Date started 20 APR 2005  
 Date completed 22 APR 2005

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25 ft</u>		<u>1.0</u>

Signed Jack Watson  
 By driller performing actual drilling on site or contractor  
 Date 6 MAY 05

Contractor  
 Address BLAIN DRILLING & PUMP CO. INC.  
P.O. Box 1255  
Carson City, NV 89702  
 Nevada contractor's license number 46498  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167  
 Signed Jack Watson  
 By driller performing actual drilling on site or contractor  
 Date 6 MAY 05