

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 54051

1. OWNER Jim Butler ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____
 2. LOCATION SW 1/4 SE 1/4 Sec. 13 T. 17 N/S R. 22 E County Lyon
 PERMIT NO. _____ Parcel No. 15-324-18 Subdivision Name Tommas Lyon

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Gravel</u>		<u>1</u>	<u>126</u>	
<u>Gravel, coarse</u>		<u>126</u>	<u>143</u>	
<u>Gravel, coarse (some boulders)</u>		<u>143</u>	<u>215</u>	
<u>Coarse sand</u>		<u>215</u>	<u>260</u>	

8. WELL CONSTRUCTION
 Depth Drilled 258 Feet Depth Cased 259 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 1 Feet 100 Feet
8 3/4 Inches 100 Feet 260 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 1/2</u>	<u>13</u>	<u>1.88</u>	<u>1</u>	<u>21</u>
<u>6 1/2</u>	<u>13</u>	<u>1.88</u>	<u>21</u>	<u>260</u>

Perforations:
 Type perforation Machine Pipe
 Size perforation 3/16 x 16 x 5 rows
 From 180 feet to 200 feet
 From 200 feet to 260 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 100
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 110 feet to 260 feet

9. WATER LEVEL
 Static water level 180 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Tommas Lyon Inc Contractor
 Address 20 599 Contractor
88 NV 89429
 Nevada contractor's license number issued by the State Contractor's Board 0031841
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876
 Signed _____
 By driller performing actual drilling on site or contractor
 Date 1/16/05

Date started 12/28/04 20 _____
 Date completed 1/2/05 20 _____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>10-12</u>	<u>2 1/2 hrs</u>	