COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 96535
Permit No.
Basin 212

NOTICE OF INTENT NO. 29372

1. OWNER 3700 ASSOCIATES LLC
MAILING ADDRESS 667 MADISON AVE
NEW YORK, NY 10021-8029

ADDRESS AT WELL LOCATION 3698 S. LAS VEGAS BLVD.
LAS VEGAS, NV

2. LOCATION SW ¼ NE ¼ Sec 20 T 21 S R 61 E CLARK County

PERMIT NO. DW1195 (Issued by Water Resources) | 162-20-603-007 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other Dewater

4. PROPOSED USE Dewater
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
2-Dewatering wells				
Asphalt		0'	3"	3"
Brown dirt		3"	8'	7'-9"
Caliche		8'	14'	6'
Brown silt	xx	14'	17'	3'
Brown silty clay		17'	21'	4'
White clay		21'	26'	6'
Red clay		26'	28'	2'
Brown clay		28'	34'	6'
White silty clay		34'	41'	7'
Brown clay & small rock		41'	50'	9'
Red clay		50'	53'	3'
White clay		53'	59'	6'
Caliche		59'	62'	3'
Brown clay & silt		62'	68'	6'
White clay & rock		68'	74'	6'
Red clay & rock		74'	80'	6'

DOWNTOWN RECEIVED MAY 16 2005 LASVEGASOFFICE

Date started 5/9, 20 05
Date completed 5/10, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 80' Feet Depth Cased 80' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
24" Inches	0 Feet	80 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation Machine
Size perforation .25"x2.5x3 rows @13
From 40' feet to 80' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 0 feet to 80 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. (CONTRACTOR)
Address 4015 WEST TOMPKINS AVE. (CONTRACTOR)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18916 & 18917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS2161
Signed [signature]
By driller performing actual drilling on site or contractor
Date 5-12-05

(Rev 12/01) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com