

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT



OFFICE USE ONLY

Log No. 910577
 Permit No. _____
 Basin 070

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 52501

1. OWNER Michael and Jessie Wilson
 MAILING ADDRESS P.O. Box 932
Carson City, NV 89702
 ADDRESS AT WELL LOCATION 8340 Elk Road
Winnemucca, NV 89445

2. LOCATION 1/4 SE 1/4 Sec 30 T 35 N R 37 E Humboldt County
 PERMIT NO. 14-262-05

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	3	3
Sand/clay		3	10	7
Coarse gravel and cobbles		10	20	10
Cobbles and sand		20	85	65
Hard rock		85	89	4
Cobbles and gravel		89	92	3
Sand and gravel		92	115	23
Cobbles		115	120	5
Sand and gravel		120	145	25
Gravel		145	150	5

8. WELL CONSTRUCTION

Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

From	To
10 5/8 Inches	0 Feet
Inches	Feet
Inches	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	188	+1	19'
6.625	4.06	.316	19	150

Perforations:
 Type perforation Factory cut
 Size perforation 0.50

From 130 feet to 150 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 55' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 55' feet to 150 feet

9. WATER LEVEL
 Static water level _____ 75' feet below land surface
 Artesian flow _____ N/A G.P.M. N/A P.S.I.
 Water temperature Cool °F Quality Good

Date started April 27, 20 05
 Date completed April 29, 20 05

7. WELL TEST DATE

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input checked="" type="checkbox"/> Air Lift
	Draw Down (Feet Below Static)		Time (Hours)
G.P.M.	<u>20</u>		<u>5</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fred Anderson & Sons Drilling, Inc.
 Address 10760 Grass Valley Road
Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 021467
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
 Signed _____
 By driller performing actual drilling on site or contractor
 Date April 30, 2005

RECEIVED
 05 MAY 19 AM 11:13
 STATE ENGINEERS OFFICE