WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 96680
Permit No.
Basin 175

NOTICE OF INTENT NO. 56152

1. OWNER ED BEAMAN
MAILING ADDRESS HC 38, BOX 171
MT CHARLESTON, NV 89124

ADDRESS AT WELL LOCATION SHANTY TOWN
Tract 7

2. LOCATION ~~NW~~ 1/4 ~~SE~~ 1/4 Sec. 1 T ~~21N~~ 26N N/S R 57E E ELKO County
PERMIT NO. SE NW (Issued by Water Resources) | 006-45A-009 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
LOOSE COBBLE CLAY		0	8	8
HARD ROCK		8	12	4
FRACTURED ROCK		12	82	70
HARD ROCK		82	93	11
LOOSE ROCK & GRAVEL	X	93	95	2
HARD ROCK		95	115	20

RECEIVED
05 MAY 31 PM 1:19
STATE ENGINEERS OFFICE

Date started 5/14/2005 , 19__
Date completed 5/20/2005 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	45		3

8. WELL CONSTRUCTION
Depth Drilled 115 Feet Depth Cased 115 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	115	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+1	15
6	SDR17		15	115

Perforations:
Type perforation SCREEN
Size perforation .050
From 95 feet to 115 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout
Bentonite GROUT 15'-50'
Gravel Packed: [X] Yes [ ] No
From 50 feet to 115 feet

9. WATER LEVEL
Static water level 35 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SHAREL C. FERTIG SR., DBA FERTIG DRILLING CO. (Contractor)
Address P.O. BOX 525 (Contractor)
ELKO, NEVADA 89803
Nevada contractor's license number issued by the State Contractor's Board 0031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed (By driller performing actual drilling on-site or contractor)
Date 5/24/2005

USE ADDITIONAL SHEETS IF NECESSARY