

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 96618
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **29335**

1. OWNER **STEVE ARNOLD**
 MAILING ADDRESS **831 S WARREN**
PAHRUMP, NV

ADDRESS AT WELL LOCATION **831 S WARREN**

2. LOCATION SW 1/4 SW 1/4 Sec. 14 T 20S
 PERMIT NO. 41-492-16

N/S R 52E E NYE County
GOLDEN SPRING RANCH UNIT3
 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILT		0	3	3
CLAY		3	10	7
CALICHE		10	30	20
CLAY		30	70	40
CALICHE	WB	70	85	15
CLAY		85	104	19
CALICHE	WB	104	116	12
CLAY		116	130	14
CALICHE	WB	130	138	8
CLAY		138	149	11
SAND & GRAVEL	WB	149	200	51

8. WELL CONSTRUCTION

Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>3.63</u>	<u>.250</u>	<u>0</u>	<u>200</u>

Perforations:
 Type perforation **SAWCUT**
 Size perforation 1/8 X 3
 From 140 feet to 200 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL
 Static water level 53 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **GREAT BASIN DRILLING CO. OF NEVADA, INC.** Contractor
 Address **P.O. BOX 4220** Contractor
PAHRUMP, NV, 89048
 Nevada contractor's license number issued by the State Contractor's Board **47333**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1426**
 Signed *[Signature]*
 By driller performing actual drilling on-site or contractor
 Date **5/19/05**

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR/DWR RECEIVED
JUN 02 2005
LAS VEGAS OFFICE

Date started 5/18/2005, 19
 Date completed 5/19/2005, 19