

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 96619
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29352

1. OWNER STANLEY ARACHIKAVITZ ADDRESS AT WELL LOCATION 2571 W WILSON RD
 MAILING ADDRESS 2571 W WILSON RD
PAHRUMP, NV

2. LOCATION NW 1/4 SE 1/4 Sec. 18 T 20S N/S R 53E E NYE County
 PERMIT NO. 36-201-03 Parcel No. CHARLESTON PARK RANCHOS UNIT 5 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	18	18
CALICHE		18	24	6
CLAY		24	50	26
CALICHE	WB	50	65	15
CLAY		65	90	25
CALICHE	WB	90	112	22
CLAY		112	140	28
CALICHE	WB	140	158	18
CLAY		158	175	17
CALICHE	WB	175	190	15
CLAY		190	200	10

DCNR/DWR RECEIVED

JUN 02 2005

LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet
0 Feet 200 Feet
 Inches Feet Feet Feet
 Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	200

Perforations:
 Type perforation SAWCUT
 Size perforation 1/8 X 3

From	<u>100</u>	feet to	<u>120</u>	feet
From	<u>140</u>	feet to	<u>160</u>	feet
From	<u>180</u>	feet to	<u>200</u>	feet
From		feet to		feet
From		feet to		feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL
 Static water level 53 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
 Address P.O. BOX 4220 Contractor
PAHRUMP, NV, 89048
 Nevada contractor's license number issued by the State Contractor's Board 47333
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426

Signed [Signature]
 By driller performing direct drilling on-site or contractor
 Date 5/17/05

Date started 5/17/2005, 19
 Date completed 5/17/2005, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.		Time (Hours)
	Draw Down (Feet Below Static)		
<input type="checkbox"/> Bailor			
<input type="checkbox"/> Pump			
<input type="checkbox"/> Air Lift			