WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 96620
Permit No. 46965
Basin 162

NOTICE OF INTENT NO. 28178

1. OWNER CIRCLE S FAMILY TRUST
MAILING ADDRESS 1300 W BASIN
PAHRUMP, NV

ADDRESS AT WELL LOCATION 1300 W BASIN

2. LOCATION SW 1/4 SE 1/4 Sec. 8 T 20S N/S R 53E E NYE County
PERMIT NO. 46965 (Issued by Water Resources) 36-041-31 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [X] Other PLUGGIN

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
PERF WELL HOLTZ AIR				
PREFORATOR FROM 140 TO				
50FT. PUMP BENTONITE				
FROM 140 TO 25FT PUMP				
NEAT CEMENT FROM 25 TO				
SURFACE				

DCNR/DWR
RECEIVED
JUN 0 2 2005
LAS VEGAS OFFICE

Date started 5/10/2005 , 19__
Date completed 5/10/2055 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches		Feet		Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation HOLTZ AIR PREFORATOR
Size perforation 1/4 X 3
From 140 feet to 50 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 140
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address P.O. BOX 4220 (Contractor)
PAHRUMP, NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed (By driller performing actual drilling on-site or contractor)
Date 5/16/05

USE ADDITIONAL SHEETS IF NECESSARY