WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 96660
Permit No.
Basin 162

NOTICE OF INTENT NO. 28518

1. OWNER SPALDING CONSTRUCTION
MAILING ADDRESS 4920 W RETREAD RD
PAHRUMP, NV

ADDRESS AT WELL LOCATION 4920 W RETREAT RD

2. LOCATION NW 1/4 SW 1/4 Sec. 14 T 20S N/S R 52E E NYE County
PERMIT NO. (Issued by Water Resources) 41-482-19 (Parcel No.) GOLDEN SPRING RANCH #3 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	13	13
CALICHE		13	34	21
CLAY		34	82	48
CALICHE	WB	82	84	2
CLAY		84	132	48
CALICHE	WB	132	138	6
CLAY		138	149	11
CALICHE	WB	149	154	5
CLAY		154	164	10
CALICHE	WB	164	200	36

DCNR/DWR
RECEIVED
JUN 14 2005
LAS VEGAS OFFICE

Date started 6/2/2005, 19__
Date completed 6/2/2005, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10.25	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	200

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3
From 140 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 76 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address P.O. BOX 4220 (Contractor)
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dam (By driller performing actual drilling on-site or contractor)
Date 6/3/2005

USE ADDITIONAL SHEETS IF NECESSARY