

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 96741
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28194

1. OWNER CRHomes ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1531 W. Ambler Way 1531 W. Ambler Way
Pahrump, NV 89060

2. LOCATION NE 1/4 SW 1/4 Sec. 20 T 19S N/S R 53E E Nye County
 PERMIT NO. _____ 29-394-04 Crystalaire Estates
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE

New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other Municipal/Industrial Monitor Stock Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>brown sandy loam</u>		<u>0</u>	<u>27</u>	<u>27</u>
<u>See next line</u>		<u>27</u>	<u>32</u>	<u>5</u>
<u>sandy loam with caleche strings</u>				
<u>brown loam</u>	<u>x</u>	<u>32</u>	<u>75</u>	<u>43</u>
<u>brown caleche</u>	<u>x</u>	<u>75</u>	<u>146</u>	<u>71</u>
<u>brown caleche</u>	<u>x</u>	<u>146</u>	<u>149</u>	<u>3</u>
<u>brown loam</u>	<u>x</u>	<u>149</u>	<u>200</u>	<u>51</u>

8. WELL CONSTRUCTION

Depth Drilled 200 Feet Depth Cased 200+1 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>11</u>	<u>0</u>	<u>200</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>3.7</u>	<u>.280</u>	<u>0</u>	<u>200</u>

Perforations:
 Type perforation sawcut
 Size perforation .188

From	feet to	feet
<u>160</u>	<u>200</u>	

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL

Static water level 70 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality good

OWNER RECEIVED
 MAY 23 2005
LASVEGASOFFICE

Date started 3/14/05, 19____
 Date completed 3/14/05, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor
 Address 5801 S. Homestead Contractor
Pahrump, NV 89048

Nevada contractor's license number issued by the State Contractor's Board 40277

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086

Signed [Signature] By driller performing actual drilling on-site or contractor
 Date 3-17-05

Signed [Signature] By driller performing actual drilling on site or contractor
 Date 05-24-05