WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 96769
Permit No.
Basin 213

NOTICE OF INTENT NO. 27,571

1. OWNER Kent Werly
MAILING ADDRESS HCR-62 Box 20B
Searchlight, Nv. 89046

ADDRESS AT WELL LOCATION
14825 Eldorado
Nelson, Nv 89046

2. LOCATION NW ¼ NW ¼ Sec. 9 T. 26 N/S R. 64 E. Clark County
PERMIT NO. Issued by Water Resources | 228-09-000-001 Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand, gravel | | 0 | 16 | 16 |
| Clay | | 16 | 26 | 10 |
| Red Volcanics | | 26 | 130 | 104 |
| Gray Volcanics | X | 130 | 300 | 170 |

DCNR/DWR
RECEIVED
JUN 15 2005
LAS VEGAS OFFICE

Date started Apr. 6, 2005
Date completed Apr. 8, 2005

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| Apr. 8 | 150 | | 1 hr |

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 20 Inches | | 0 Feet | 20 Feet |
| 12 Inches | | 20 Feet | 50 Feet |
| 8 Inches | | 50 Feet | 300 Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 12 | | .250 | 0 | 20 |
| 8 | | .188 | +2 | 50 |
| 6 | SDR | 21 | 5 | 300 |

Perforations:
Type perforation Factory Screen
Size perforation .032
From 200 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout
Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level 4.3' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Webber Drilling Contractor
Address 2475 W. 3935 S. Contractor
WVC 84119
Nevada contractor's license number issued by the State Contractor's Board 0025887
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2238
Signed Bryan Anzalone
By driller performing actual drilling on site or contractor
Date May 10, 2005

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627