

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO **26887**

1. OWNER **SASKIA RAEVOURI** ADDRESS AT WELL LOCATION **1080 W ERETA PAHRUMP N.V.**
 MAILING ADDRESS **3890 VISTA CAMPANA SOUTH #3 OCEANSIDE CALIF 92057**
 2. LOCATION **NE 1/4 SE 1/4 Sec. 32 T. 19 N/S R. 53 E. NYE** County
 PERMIT NO. **029-811-09** **RANCHO DEL SOL** Subdivision Name
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-------------------|--------------|------|-----|------------|
| BRN CLAY | | 0 | 16 | 16 |
| CALICHE | | 16 | 19 | 3 |
| BRN CLAY | | 19 | 62 | 43 |
| CALICHE | | 62 | 64 | 2 |
| BRN CLAY | X | 64 | 160 | 96 |
| BRN CLAY + GRAVEL | X | 160 | 175 | 15 |
| BRN CLAY | X | 175 | 180 | 5 |

WATER 72°

UNRECEIVED

MAY 23 2005

LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled **180** Feet Depth Cased **180** Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 Inches **0** Feet **180** Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| 6 | | SCH-40 | 0 | 180 |

Perforations:
 Type perforation **SAW CUT**
 Size perforation **1/8 x 6"**
 From **120** feet to **170** feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From **50** feet to **180** feet

9. WATER LEVEL
 Static water level **67** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **Cold** °F Quality **Good**

Date started **5-16** **2005**
 Date completed **5-20** **2005**

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|-----------|-------------------------------|----------------|
| 30 | 5' | 1/2 HRS |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **LARRY'S WATER WELL SERVICE** Contractor
 Address **PO BOX 3392** Contractor
PAHRUMP N.V.
 Nevada contractor's license number issued by the State Contractor's Board **6035901**
 Nevada driller's license number issued by the Division of Water Resources, the on site driller **1916**
 Signed **Larry Benjamin**
 By driller performing actual drilling on site or contractor
 Date **5-23-05**