WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 96771
Permit No. 70430
Basin 210

NOTICE OF INTENT NO. 25679

1. OWNER Coyote Springs Investment
MAILING ADDRESS 6295 Wingfield Spring Rd.
Sparks, NV 89436

ADDRESS AT WELL LOCATION 2 miles East of 93, Hwy 168

2. LOCATION SW ¼ SE ¼ Sec. 22 T. 13 N/S R. 63 E. Clark County

PERMIT NO. 70430 (Issued by Water Resources) | Parcel No. 009-00-001-004 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TAN Sand - Coarse		0	60	60
TAN Sand - medium		60	80	20
TAN gravely sand		80	90	10
Pinkish Tan silty clay		90	140	50
TAN Silty clay		140	170	30
Buff silt stone		170	210	40
TAN Silty clay		210	260	50
Dark Brown clay		260	270	10
green gray clay		270	300	30
gray frac. limestone		300	314	14
Med. gray limestone		314	370	56
light gray limestone		370	440	70
pinkish gray limestone	X	440	470	30
gray fractured limestone	X	470	710	240
Dark gray limestone		710	870	160
gray fractured limestone	X	870	920	50
Dark gray limestone		920	935	15
Note: Concrete seal from 935' to 920' per NAC regs.				

DCNR/DWR RECEIVED MAY 26 2005 LASVEGAS OFFICE

Date started 3-29-1, 2005
Date completed 5-24, 2005

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
1400	50	4

8. WELL CONSTRUCTION
Depth Drilled 935 Feet Depth Cased 920 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
42 Inches		0 Feet	40 Feet
30 Inches		40 Feet	314 Feet
18 Inches		314 Feet	930 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
36	143	.375	0	40
24	95	.375	0	314
14	46	.312	+2	880

Perforations:
Type perforation Ful-Flo Louvered
Size perforation .150 slot
From 520 feet to 600 feet
From 640 feet to 760 feet
From 800 feet to 880 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 314
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 920 feet to 0 feet

9. WATER LEVEL
Static water level 438 feet below land surface
Artesian flow NA G.P.M. P.S.I.
Water temperature 91 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge. LAYNE CHRISTENSEN CO.
Name ~~Dolan T. Parks~~ Contractor
Address ~~PO Box 1376~~ 12030 E Riggs Rd. CHANDLER ARIZ Contractor 85249 ~~Woodland, CA 95776~~
Nevada contractor's license number issued by the State Contractor's Board 43608
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2284
Signed [signature] By driller performing actual drilling on site or contractor
Date 5-24-05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627