WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 96784
Permit No.
Basin 162

NOTICE OF INTENT NO. 28214

1. OWNER CR Homes
MAILING ADDRESS 1790 W. Moose Street
Pahrump, NV 89049

ADDRESS AT WELL LOCATION
1790 W. Moose Street

2. LOCATION NW 1/4 NW 1/4 Sec. 29 T 20S N/S R 53E E Nye County
PERMIT NO. (Issued by Water Resources) 39-032-35 (Parcel No.) Calvada Valley (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown clay		0	4	4
grey clay		4	42	38
grey loam		42	59	17
See next line	x	59	93	3
brown clay with caleche strings				
See next line	x	93	170	77
brown loam with caleche strings				
brown caleche	x	170	192	22
See next line	x	192	200	8
brown clay with caleche strings				

DCNR/DWR
RECEIVED
JUN 28 2005
LAS VEGAS OFFICE

Date started 6/3/05, 19__
Date completed 6/3/05, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200+1 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 Inches		0 Feet	200 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.7	.280	0	200

Perforations:
Type perforation sawcut
Size perforation .188
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 62 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Strickland Construction Co., Inc. (Contractor)
Address 5801 S. Homestead (Contractor)
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 6-21-05