

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 96831
 Permit No. _____
 Basin 162
 NOTICE OF INTENT NO. 28506

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OWNER PRITHYARAJ PAL
 MAILING ADDRESS 4731 E. MCGRAW
PAHRUMP, NV

ADDRESS AT WELL LOCATION 4731 E. MCGRAW RD

2. LOCATION SW 1/4 NW 1/4 Sec. 20 T 21S
 PERMIT NO. 45-292-09
 Issued by Water Resources Parcel No.

N/S R 54E E NYE County
GREEN SADDLE RANCH
 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SILT		0	8	8
CLAY		8	12	4
CALICHE		12	30	18
CLAY		30	70	40
CALICHE	WB	70	90	20
CLAY		90	115	25
CALICHE	WB	115	130	15
CLAY		130	143	13
LIMESTONE	WB	143	180	37
CLAY & GRAVEL		180	200	20

8. WELL CONSTRUCTION

Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

From		To	
<u>10</u> Inches	<u>0</u> Feet	<u>200</u> Feet	
_____ Inches	_____ Feet	_____ Feet	
_____ Inches	_____ Feet	_____ Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>3.63</u>	<u>.250</u>	<u>0</u>	<u>200</u>
_____	_____	_____	_____	_____

Perforations:
 Type perforation SAWCUT
 Size perforation 1/8 X 3
 From 120 feet to 180 feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 50
 Placement Method: Pumped Poured
 Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 200 feet

DCNR/DWR
 RECEIVED

JUN 16 2005

LAS VEGAS OFFICE

Date started 6/6/2005, 19
 Date completed 6/6/2005, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.		Time (Hours)
	Draw Down (Feet Below Static)		
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL

Static water level 68 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
 Address P.O. BOX 4220 Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board 47333
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
 Signed [Signature]
 by driller performing actual drilling on-site or contractor
 Date 6/13/2005