

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT **N07.03**

1. OWNER Bernard Lange ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____ S.W. COR. VALADEZ & HELENA
7915 Helena Ave - 08B County _____
 2. LOCATION NW 1/4 SE 1/4 Sec. T20S N/S 160 E. Clark
 PERMIT NO. 138-04-705-003 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Clay		0	210	
Caliche		210	260	
Cemented Gravel		260	315	
Gravel & Water	XX	315	340	
Cemented Gravel		340	400	
Gravel & Water	XX	400	440	
Cemented Gravel		440	510	
Gravel & Water	XX	510	550	

**DCNR/DWR
RECEIVED**

JUN 24 2005

LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 550 Feet Depth Cased 550 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 1/4 Inches 0 Feet 50 Feet
8 3/4 Inches 50 Feet 550 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+2	3
8 1/2	PVC SCH 40		-3	50
6 1/2	PVC 480		+1	550

Perforations:
 Type perforation Factory
 Size perforation .032 Sieve Type
 From 476 feet to 536 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started 6/20/05, 20 _____
 Date completed 6/24/05, 20 _____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 275 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.1 °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Vernon H. Dimick
 Contractor
 Address 5360 N. Bonita Vista
 Contractor
Las Vegas, Nevada 89149
 Nevada contractor's license number issued by the State Contractor's Board 10062
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
 Signed _____
 By driller performing actual drilling on site or contractor
 Date _____