WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 96835
Permit No.
Basin 212

NOTICE OF INTENT NO. 26015

1. OWNER John P. Lytle
MAILING ADDRESS
ADDRESS AT WELL LOCATION Kyle Canyon Rd

2. LOCATION NE ¼ NE ¼ Sec. 18 T19S N/S R Clark 859 E County
PERMIT NO. (Issued by Water Resources) 126-18-502-002 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
[xx] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[xx] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[xx] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	173	
Limestone Rock		173	415	
Limestone & Water	xx	415	440	
Solid Limestone		440	510	
Limestone & Water	xx	510	560	

DCNR/DWR
RECEIVED
JUN 24 2005
LAS VEGAS OFFICE

Date started 5/30/05, 20
Date completed 6/20/05, 20

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 560 Feet Depth Cased 560 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4 Inches	0 Feet	50 Feet
8 3/4 Inches	50 Feet	560 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8"	16.94	.188	+2	3
8 1/2"	PVC	Sch 40	-3	50
6 1/2	PVC	480	+1	560

Perforations:
Type perforation Factory
Size perforation .032 Sieve Type
From 510 feet to 550 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [x] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [xx] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [xx] Concrete Grout
Gravel Packed: [xx] Yes [ ] No
From feet to feet

9. WATER LEVEL
Static water level 375 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 60.1 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick (Contractor)
Address 5360 N. Bonita Vista (Contractor)
Las Vegas, Nevada 89149
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V. H. Dimick (By driller performing actual drilling on site or contractor)
Date 06-24-05

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627