

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 96841
Permit No. 212
Basin 26298

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26298

1. OWNER American Pacific Corp ADDRESS AT WELL LOCATION Southwest Boundary of Sec 25 Henderson, NV
 MAILING ADDRESS 3770 Howard Hughes Parkway Las Vegas, NV 89104

2. LOCATION SW 1/4 SW 1/4 Sec. 25 T. 21 N/S R. 62 E Clark County
 PERMIT NO. 161-25-401-001 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other

4. PROPOSED USE
 Domestic Municipal/Industrial Irrigation Monitor Test Stock

5. WELL TYPE
 Cable Rotary RVC Air Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
fill Silty Sand Brn		0	5 1/2	5 1/2
Alluvium Silty Sand		5	12	7
Silts Brn	x	12	17	5
Sand Brn	x	17	17 1/2	1/2
Silts Brn	x	17 1/2	22	4 1/2
Sand Brn	x	22	24	2
Silty-Clay Brn		24	35	11
Sand Brn	x	35	37	2
Caliche, gravel Grey		37	42	5
Silts Brn		42	52	10
Bertrandite Chips		43	52	9
flush mount box with 2'x2' pad				

DCNR/DWR RECEIVED
JUN 22 2005
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 52 Feet Depth Cased 42 Feet

HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 0 Feet 52 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4		Sch 40 PVC	0	22
4		PVC Screen	22	42

Perforations:
 Type perforation Screen
 Size perforation .040
 From 22 feet to 42 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout Bertrandite

Depth of Seal 20
 Placement Method: Pumped Grout chips
 Poured

Gravel Packed: Yes No
 From 20 feet to 43 feet

9. WATER LEVEL
 Static water level 10.5 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Prasonia Corporation Contractor
 Address 419 E Jannite Mesa, AZ 84205 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0051765
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1988
 Signed John Zimmerman By driller performing actual drilling on site or contractor
 Date 6/5/05

Date started 4/29, 2005
 Date completed 4/30, 2005

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)