003436

3 wells

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 96881
Permit No.
Basin 212

NOTICE OF INTENT NO. 27594

1. OWNER Frank Mikulich
MAILING ADDRESS 2779 White Sage Dr. Henderson NV
ADDRESS AT WELL LOCATION 918 Stewart Ave Las Vegas, NV

2. LOCATION SE ¼ SE ¼ Sec. 34 T. 20 N/S R. 61 E. Clark County
PERMIT NO. Issued by Water Resources
139-34-612-070 Parcel No.
Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other HSA

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Cement | | 0 | .5 | 6" |
| Type II | | .5 | 1.0 | 6" |
| Silty Sand | | 1.0 | 10.0 | 9' |
| Caliche | | 10.0 | 12.0 | 2' |
| Silty Clay | | 12 | 15 | 3' |
| Silty Sand w/gravel | | 15 | 18 | 3' |
| Silty Clay | | 18 | 25 | 7' |

DCNR/DWR
RECEIVED
JUN 28 2005
LAS VEGAS OFFICE

Date started 05/17, 2005
Date completed 05/18, 2005

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From Feet | To Feet |
|---|---|---|
| 8.5 ~~4.5~~ | 0 | 25 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2.5 | | Sch 40 PVC | 0 | 25 |
| | | | | |

Perforations:
Type perforation Machine Slotted
Size perforation 0.020
From 5 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 3
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 3 feet to 25 feet

9. WATER LEVEL
Static water level 15 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Poor

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eagle Drilling Services (Contractor)
Address 7150 Placid Las Vegas, NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2193
Signed Victor (By driller performing actual drilling on site or contractor)
Date 06/20/05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627