

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. **96936**  
 Permit No. \_\_\_\_\_  
 Basin **162**



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **28537**

1. OWNER **MARK & LORNA STREETON**  
 MAILING ADDRESS **2890 S. PAPAYA AVE PAHRUMP, NV**  
 ADDRESS AT WELL LOCATION **2890 S PAPAYA AVE**

2. LOCATION **SW** 1/4 **SE** 1/4 Sec. **28** T **20S** N/S R **53E** E **NYE** County  
 PERMIT NO. \_\_\_\_\_ Parcel No. **40-403-16** Subdivision Name **CALVADA VALLEY UNIT 5**

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	126	126
CALICHE	WB	126	128	2
CLAY		128	151	23
CALICHE	WB	151	159	8
CLAY		159	184	25
CALICHE	WB	184	191	7
CLAY		191	220	29
CALICHE	WB	220	231	11
CLAY		231	242	11
CALICHE	WB	242	260	18

DCNR/DWR  
RECEIVED  
JUL 15 2005  
LAS VEGAS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled **260** Feet Depth Cased **260** Feet

HOLE DIAMETER (BIT SIZE)  
 From **10.25** Inches To **0** Feet  
 To **260** Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/FL (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	260

Perforations:  
 Type perforation **SAWCUT**  
 Size perforation **1/8 X 3**

From <b>140</b> feet to <b>160</b> feet
From <b>180</b> feet to <b>200</b> feet
From <b>220</b> feet to <b>240</b> feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal:  Yes  No  
 Depth of Seal **50**  
 Placement Method:  Pumped  Poured  
 Seal Type:  Neat Cement  Cement Grout  Concrete Grout

Gravel Packed:  Yes  No  
 From **50** feet to **260** feet

9. WATER LEVEL  
 Static water level **78** feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started **6/29/2005**, 19\_\_\_\_  
 Date completed **6/29/2005**, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **GREAT BASIN DRILLING CO. OF NEVADA, INC.** Contractor  
 Address **P.O. BOX 4220** Contractor  
**PAHRUMP, NV, 89048**

Nevada contractor's license number issued by the State Contractor's Board **47333**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1642**

Signed *[Signature]*  
 By driller performing actual drilling on-site or contractor

Date **6/30/2005**