WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 96939
Permit No. 64887
Basin 162

NOTICE OF INTENT NO. 28544

OWNER MARK BOWMAN
MAILING ADDRESS 5560 S MILLER RD
PAHRUMP, NV

ADDRESS AT WELL LOCATION 5560 S MILLER RD

2. LOCATION NE 1/4 SW 1/4 Sec. 10 T 21S N/S R 54E E NYE County
PERMIT NO. 64887 Issued by Water Resources
45-121-06 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. COMMERCIAL - DSB
[X] ~~Domestic~~ [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND & GRAVEL & ROCK		0	125	125
CLAY & GRAVEL		125	138	13
SAND & GRAVEL	WB	138	142	4
CLAY & GRAVEL		142	185	43
SAND & GRAVEL	WB	185	190	5
CLAY & GRAVEL		190	230	40
SAND & GRAVEL	WB	230	236	6
CLAY & GRAVEL		236	245	9
SAND & GRAVEL	WB	245	300	55

RECEIVED
DCNR/DWR
RECEIVED
JUL 15 2005
STATE ENGINEER'S OFFICE
LAS VEGAS OFFICE

Date started 6/24/2005, 19__
Date completed 6/24/2005, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 6/24/2005 Feet Depth Cased 6/24/200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	300	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	300

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3
From 180 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 0 feet to 300 feet

9. WATER LEVEL
Static water level 51 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
Address P.O. BOX 4220 Contractor
PAHRUMP, NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 71426
Signed By driller performing actual drilling on-site or contractor
Date 6/24/2005

USE ADDITIONAL SHEETS IF NECESSARY