

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **27704**

1. OWNER **PART WALKER** ADDRESS AT WELL LOCATION **9140 W. WASHBURN**
 MAILING ADDRESS **P.O. Box 80235**
L.V. NV. 89180
 2. LOCATION **SW 1/4 NW 1/4 Sec. 32 T. 19 S. R/S R. 60 E. CLARK** County
 PERMIT NO. **125-32-205-008** Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
GRAVEL-Cemented		0	10	
GRAVEL		10	12	
Cemented GRAVEL		12	45	
CLAY + GRAVEL		45	210	
GRAVEL		210	240	
Cemented GRAVEL		240	295	
CLAY GRAVEL		295	345	
GRAVEL + WATER	X	345	360	
Cemented GRAVEL		360	420	
GRAVEL + WATER	X	420	440	
Cemented GRAVEL		440	480	
GRAVEL + WATER	X	480	510	

**DCNR/DWR
RECEIVED**

JUL 18 2005

LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled **510** Feet Depth Cased **510** Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 1/4 Inches **0** Feet **6.0** Feet
8 3/4 Inches **6.0** Feet **5.10** Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+ 2	- 3
8 1/2	PVC		- 3	50
6 1/2	PVC		+ 1	510

Perforations:
 Type perforation **Factory**
 Size perforation **.032 / sieve Type**
 From **460** feet to **500** feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal **50**
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level **281** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **Cool** °F Quality _____

Date started **07-01-05**, 20
 Date completed **07-14-05**, 20

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **VERNON H. DIMICK** Contractor
 Address **5360 N. BONITA VISTA ST. LAS VEGAS, NEV. 89149** Contractor
 Nevada contractor's license number issued by the State Contractor's Board **10062**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **552**
 Signed **V.H. Dimick**
 By driller performing actual drilling on site or contractor
 Date **07-14-05**