COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 96974
Permit No.
Basin 212

NOTICE OF INTENT NO. 27366

1. OWNER COUNTY OF CLARK (UMC)
MAILING ADDRESS 1800 W CHARLESTON BLVD
LAS VEGAS, NV 89102

ADDRESS AT WELL LOCATION 1800 W CHARLESTON BLVD

2. LOCATION SW ¼ SW ¼ Sec 33 T 20 S R 61 E CLARK County

PERMIT NO. DW1194 (Issued by Water Resources) | 139-33-405-001 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other Dewater

4. PROPOSED USE Dewater
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| 2-Dewater wells | | | | |
| Silt | | 0 | 8 | 8 |
| Caliche | | 8 | 12 | 4 |
| Gray silty clay | | 12 | 19 | 7 |
| Brown clay | | 19 | 30 | 11 |

DCNR/DWR
RECEIVED
JUL 20 2005
LAS VEGAS OFFICE

Date started 6/9, 20 05
Date completed 6/9, 20 05

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 24 Inches | 0 Feet | 30 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| | | | | |

Perforations:
Type perforation Machine
Size perforation 1/4"x2.5 x 21 per ft.
From 20 feet to 30 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: ☐ Yes ☐ No Seal Type:
Depth of Seal _____ ☐ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 0 feet to 40 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow _____ G.P.M _____ P.S.I
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. (CONTRACTOR)
Address 4015 WEST TOMPKINS AVE. (CONTRACTOR)
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18916 & 18917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS2161
Signed _____ By driller performing actual drilling on site or contractor
Date 78/05


Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com