

Log No. 96992  
 Permit No. \_\_\_\_\_  
 Basin 137B

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 55158

1. OWNER ROUND MOUNTAIN GOLD CORP. ADDRESS AT WELL LOCATION R.M.G.C.  
 MAILING ADDRESS P.O. BOX 480 ROUND Mtn AV.  
ROUND Mtn. NV. 89045  
 2. LOCATION NW 1/4 SW 1/4 Sec. 19 T. 10 N/S R. 44 E. NYE County  
 PERMIT NO. 72250-T Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. WELL # SOW 2 LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>ALLUV</u>		<u>0'</u>	<u>70'</u>	<u>70'</u>
<u>VOLCANIC</u>		<u>75'</u>	<u>100'</u>	<u>25'</u>
<u>SUPER PLUG</u>		<u>75'</u>	<u>100'</u>	<u>25'</u>
<u>TRANS. SAND (60)</u>		<u>70'</u>	<u>75'</u>	<u>5'</u>
<u>1/4" SAND</u>		<u>25'</u>	<u>70'</u>	<u>45'</u>
<u>MED GIBBONITE CHIP</u>		<u>10'</u>	<u>25'</u>	<u>15'</u>
<u>HEAT CEMENT</u>		<u>0'</u>	<u>10'</u>	<u>10'</u>

8. WELL CONSTRUCTION  
 Depth Drilled 100' Feet Depth Cased 100' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10" Inches To 0' Feet 100' Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>		<u>SCH 80</u>	<u>+2.5'</u>	<u>100'</u>

Perforations:  
 Type perforation HORIZ. SLOT  
 Size perforation .020  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 30' feet to 70' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 10'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 25' feet to 70' feet

9. WATER LEVEL  
 Static water level 59.7' feet below land surface  
 Artesian flow N/A G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name ELKUND DRILLING Contractor  
 Address P.O. BOX 2748 Contractor  
ELKO NV. 89803  
 Nevada contractor's license number issued by the State Contractor's Board 30923  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1698  
 Signed Jay Jaye Harris  
 Driller performing actual drilling on site or contractor  
 Date 5-4-05

Date started 4-15, 2005  
 Date completed 4-15, 2005

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>LESS THAN ONE G.P.M.</u>			