

Log No. 96994  
Permit No. \_\_\_\_\_  
Basin. 137B

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 55158

1. OWNER ROUND MOUNTAIN GOLD CORP. ADDRESS AT WELL LOCATION R.M. 6.C.  
MAILING ADDRESS P.O. BOX 480 ROUND Mtn NV.  
ROUND Mtn NV. 89045

2. LOCATION NW 1/4 SW 1/4 Sec 19 T. 10 N/S R. 44 E NYE County  
PERMIT NO. 72252-T Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>WELL# SDW-23</u>				
<u>ALLUV.</u>		<u>0'</u>	<u>75'</u>	<u>75'</u>
<u>VOLCANIC</u>		<u>75'</u>	<u>90'</u>	<u>15'</u>
<u>SUPER PLUG</u>		<u>75'</u>	<u>90'</u>	<u>15'</u>
<u>TRANS. SAND (G)</u>		<u>70'</u>	<u>75'</u>	<u>5'</u>
<u>1/4 SAND</u>		<u>25'</u>	<u>70'</u>	<u>45'</u>
<u>MED. DENTONITE CHIP</u>		<u>25'</u>	<u>10'</u>	<u>15'</u>
<u>NEAT CEMENT</u>		<u>0'</u>	<u>10'</u>	<u>10'</u>

8. WELL CONSTRUCTION  
Depth Drilled 90' Feet Depth Cased 90' Feet  
HOLE DIAMETER (BIT SIZE)  
From 0' To 90'  
10" Inches 0' Feet 100' Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>		<u>5CH 90.</u>	<u>0'</u>	<u>90'</u>

Perforations:  
Type perforation HORIZ. SLOT  
Size perforation .020  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From 30' feet to 70' feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 10  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 25' feet to 70' feet

9. WATER LEVEL  
Static water level 60.9' feet below land surface  
Artesian flow N/A G.P.M. P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 4-27, 2005  
Date completed 4-27, 2005

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>LESS THAN ONE G.P.M.</u>			

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name EKLUND DRILLING Contractor  
Address P.O. BOX 2748 Contractor  
ELMO NV. 89803  
Nevada contractor's license number issued by the State Contractor's Board 30823  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1698  
Signed Jay Jaye Harris  
By  performing actual drilling on site or contractor  
Date 5-4-05