WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46996
Permit No.
Basin 137B

NOTICE OF INTENT NO. 55158

1. OWNER ROUND MOUNTAIN GOLD CORP.
MAILING ADDRESS P.O. BOX 480
ROUND MTN NV. 89045

ADDRESS AT WELL LOCATION RMGC.
ROUND MTN NV.

2. LOCATION NW ¼ SW ¼ Sec. 19 T 10 N/S R 44 E NYE County
PERMIT NO. 72254-T (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☑ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
WELL # SDW-25		0'	80'	80'
ALLUV.				
VOLCANIC		80'	100'	20'
SUPER PLUG	80'	100		20'
TRANS. SAND (60)		75'	80'	5'
1/4" SAND		~~45'~~ 25'	~~75'~~ 75'	~~30'~~ 50'
MED. BENTONITE CHIP		10'	25'	15'
NEAT CEMENT		0'	10'	10'

Date started 4-18, 2005
Date completed 4-18, 2005

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
LESS THAN	ONE G.P.M.	

8. WELL CONSTRUCTION
Depth Drilled 100' Feet Depth Cased 100' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10" Inches		0' Feet	100' Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"		SCH 80	~~0'~~ +2.5'	100'

Perforations:
Type perforation HORIZ. SLOT
Size perforation .020
From feet to feet
From 45' feet to 75' feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 10
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 25' feet to 75' feet

9. WATER LEVEL
Static water level 57.38' feet below land surface
Artesian flow N/A G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ELKUHO DRILLING (Contractor)
Address P.O. BOX 2748 (Contractor)
ELKO NV. 89803
Nevada contractor's license number issued by the State Contractor's Board 30823
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1698
Signed Gary Jayne Harris (By driller performing actual drilling on site or contractor)
Date 5-04-05

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627