

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 97001  
 Permit No. \_\_\_\_\_  
 Basin 137B

NOTICE OF INTENT NO. 55159

1. OWNER ROUND MOUNTAIN GOLD CORP. ADDRESS AT WELL LOCATION R.M.G.C.  
 MAILING ADDRESS P.O. BOX 480 ROUND MTN. NV.  
ROUND MTN. NV. 89045  
 2. LOCATION NW 1/4 SW 1/4 Sec 19 T 10 N/S R 44 E NYE County  
 PERMIT NO. 72259-7 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>WELL# SDW-30</u>				
<u>ALLUV.</u>		<u>0</u>	<u>85'</u>	<u>85'</u>
<u>VOLCANIC</u>		<u>85'</u>	<u>105'</u>	<u>20'</u>
<u>SUPER PLUG</u>		<u>85'</u>	<u>105'</u>	<u>20'</u>
<u>TRANS SAND (60)</u>		<u>80'</u>	<u>85'</u>	<u>5'</u>
<u>1/4" SAND</u>		<u>40'</u>	<u>80'</u>	<u>40'</u>
<u>M&amp;B BENTONITE CHIP</u>		<u>10'</u>	<u>40'</u>	<u>30'</u>
<u>NEAT CEMENT</u>		<u>0</u>	<u>10'</u>	<u>10'</u>

8. WELL CONSTRUCTION  
 Depth Drilled 105' Feet Depth Cased 105' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10" Inches To 0' Feet 105' Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>		<u>SC480</u>		

Perforations:  
 Type perforation HORIZ. SLOT  
 Size perforation 1020  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 40' feet to 80' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 10'  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 40' feet to 80' feet

9. WATER LEVEL  
 Static water level 54.7' feet below land surface  
 Artesian flow N/A G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ELKHO DRILLING Contractor  
 Address P.O. BOX 2748 Contractor  
ELKO NV. 89803  
 Nevada contractor's license number issued by the State Contractor's Board 30823  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1698  
 Signed Ray James Harris  
 By Driller performing actual drilling on site or contractor  
 Date 5-4-05

Date started 4/6, 2005  
 Date completed 4/6, 2005

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>LESS THAN ONE G.P.M.</u>			