

OFFICE USE ONLY
 Log No. 97003
 Permit No. _____
 Basin 137B

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 55158

1. OWNER ROUND MOUNTAIN GOLD CORP ADDRESS AT WELL LOCATION R.M.G.C Round Mtn
 MAILING ADDRESS P.O. BOX 480
ROUND Mtn. NV. 89045
 2. LOCATION NW 1/4 SW 1/4 Sec 19 T 10 N/S R 44 E NYE County
 PERMIT NO. 72261-7 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>WELL # SDW-32</u>				
<u>ALLUV.</u>		<u>0</u>	<u>70'</u>	<u>70'</u>
<u>VOLCANIC</u>		<u>70'</u>	<u>116'</u>	<u>46'</u>
<u>SUPER PLUG</u>		<u>70'</u>	<u>116'</u>	<u>46'</u>
<u>TRANS SAND (60)</u>		<u>65'</u>	<u>70'</u>	<u>5'</u>
<u>1/4" SAND</u>		<u>25'</u>	<u>65'</u>	<u>40'</u>
<u>MAR. BRADWATECHIP</u>		<u>10'</u>	<u>25'</u>	<u>15'</u>
<u>NEAT CEMENT</u>		<u>0</u>	<u>10'</u>	<u>10'</u>

8. WELL CONSTRUCTION
 Depth Drilled 116' Feet Depth Cased 116' Feet
 HOLE DIAMETER (BIT SIZE)
 From 10" Inches To 116' Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>		<u>SCH 80</u>	<u>+2.5'</u>	<u>116'</u>

 Perforations:
 Type perforation HORIZ SLOT
 Size perforation .020
 From _____ feet to _____ feet
 From 25' feet to 65' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 10 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 25' feet to 65' feet

Date started 4/5, 2005
 Date completed 4/5, 2005

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>LESS THAN ONE G.P.M.</u>			

9. WATER LEVEL
 Static water level 44.4' feet below land surface
 Artesian flow N/A G.P.M. _____ P.S.I. _____
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ELKHO DRILLING Contractor
 Address P.O. BOX 2748 Contractor
ELKO NV. 89803
 Nevada contractor's license number issued by the State Contractor's Board 30823
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1698
 Signed Ray Jaye Harris
 By driller performing actual drilling on site or contractor
 Date 5-4-05