WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 97007
Permit No.
Basin 059

NOTICE OF INTENT NO. 55018

1. OWNER Newmont Mining Corp
MAILING ADDRESS P.O. Box 388
Valmy, NV 89438

ADDRESS AT WELL LOCATION 16 miles So. of Battle Mtn at the Phoenix Project CM-42

2. LOCATION NE ¼ SW ¼ Sec. 33 T. 31 N/S R. 43 E. Lander County

PERMIT NO. | Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Tripped in 320' of trimmie | | | | |
| Pumped through trimmie | | | | |
| approx. 78.3 gal of cement | | | | |
| using 15 Sacks of 94lbs | | | | |
| Portland cement. Filled | | | | |
| well completely w/neat | | | | |
| cement Avg. 15lbs/gal | | | | |

Date started 4-7, 2005
Date complated 4-7, 2005

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| | | | |

8. WELL CONSTRUCTION
Depth Drilled 340 Feet Depth Cased 340 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| Inches | Feet | Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2.375 | PVC | Sch 80 | 0 | 340 |
| | | | | |
| | | | | |

Perforations:
Type perforation slotted
Size perforation .020
From 260 feet to 340 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 340
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 273.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Eklund Drilling Co (Contractor)
Address P.O. Box 2748 (Contractor)
Elko, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 0030823

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1769

Signed Warren Hartley
By driller performing actual drilling on site or contractor

Date 4-28-05

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627